FLINT CULTURAL CENTER ACADEMY

A Notice to Parents, Guardians, and Staff

Lead Testing of Our School Drinking Water

September 1, 2025

Flint Cultural Center Academy
1200 Robert T. Longway Blvd.
Flint, MI 48503

Dear Parents, Guardians, and Staff:

The Flint Cultural Center Academy (FCCA) places student and staff safety as the highest priority. To attend to the health and wellbeing of all our students and staff, we have placed a high level of attention on quality drinking water in our schools. We are committed to achieving top-level quality drinking water in our facility and continue to take action to achieve top-level water quality results. Therefore, we have decided to test our drinking water for lead at all water locations that are used for drinking or food preparation. Please read this notice closely to see what we are doing to proactively investigate and reduce the risk of lead exposure in our drinking water.

Why Test School Drinking Water for Lead?

There is no known safe level of lead exposure. Children younger than six years old are at the highest risk due to their rapid rate of growth and ongoing brain development. Exposure to lead can cause damage to the brain, nervous system, red blood cells, and kidneys. Lead also has the potential to cause lower IQs, hearing impairments, reduced attention span, hyperactivity, developmental delays, and poor classroom performance. Pregnant women and their fetuses are especially vulnerable to lead exposure since lead can significantly harm the fetus, causing lower birth weight and slowing normal mental and physical developments.

When was Sampling Done?

We are taking proactive steps to assure healthy water is provided throughout our school. We tested the water from every outlet that is being or could potentially be used for drinking or cooking for lead on August 7, 2025. Samples were collected by Michigan Department of Health & Human Services staff according to United States Environmental Protection Agency and Michigan Department of Environment, Great Lakes and Energy (EGLE) guidelines, and corrective measures will be immediately taken for any results indicating elevated lead concentrations.

Testing results are included in this communication by clicking the following link.

How Can I Learn More?

For information about water quality and sampling for lead at home, contact your local water supplier or state drinking water agency. You may find additional information about lead at: www.Michigan.gov/MiLeadSafe. **And, as always, feel free to contact the office of the Flint Cultural Center Academy at 810.339.8750 if you have questions or concerns.**

Sincerely,
Eric Lieske
CEO
Flint Cultural Center Academy

Facility Name: Flint Cultural Center Academy
Building (Entity) Code: 03576

Facility Water Test Results

Lead Testing Grant Program

Date: 8/7/25

			Sample Date: 7/24/25		Sample Date:		Sample Date:		Sample Date:		
Sample Sequence	**Fixture ID Code** (Sample Point field on lab report)	**Fixture Location**	**First Draw Lead Result** (mg/L) as shown on the laboratory report	**30-Second Flush Lead Result** (mg/L) ("F" at end of sample point code is 30 second flush sample)	**First Draw Lead Result** (mg/L) as shown on the laboratory report	**30-Second Flush Lead Result** (mg/L) ("F" at end of sample point code is 30 second flush sample)	**First Draw Lead Result** (mg/L) as shown on the laboratory report	**30-Second Flush Lead Result** (mg/L) ("F" at end of sample point code is 30 second flush sample)	**First Draw Lead Result** (mg/L) as shown on the laboratory report	**30-Second Flush Lead Result (mg/L) ("F" at end of sample point code is 30 second flush sample)**	**Blank test result cells indicate no sample was collected and/or fixture no longer used for consumption**
1	FCCA-1HALL-3-BFB	Bubbler part of bottle fill unit	Not detected	Not detected							
2	FCCA-1HALL-2-BF	1HALL by CR102 bottle fill	Not detected	Not detected							
3	FCCA-1HALL-4-BFB	High water cooler at bottle fill	Not detected	Not detected							
4	FCCA-1HALL-BFB	Bubbler part of bottle fill unit	Not detected	Not detected							
5	FCCA-1HALL-BF	1HALL by bathrooms bottle fill	Not detected	Not detected							
6	FCCA-1HALL-2-BFB	High water cooler at bottle fill	Not detected	Not detected							
7	FCCA-TL-TL	TL by 1HALL bathrooms	Not detected	Not detected							
8	FCCA-MST-BFB	Bubbler part of bottle fill unit	Not detected	Not detected							
9	FCCA-MST-BF	Mainstreet hall by gym-bottle fill	Not detected	Not detected							
10	FCCA-MST-2-BFB	High water cooler at bottle fill	Not detected	Not detected							
11	FCCA-KIT-KF	Kitchen faucet	Not detected	Not detected							
12	FCCA-LINK-BFB	Bubbler part of bottle fill unit	Not detected	Not detected							
13	FCCA-LINK-BF	Bottle fill-LINK hall by hall entry	Not detected	Not detected							
14	FCCA-LINK-2-BFB	High water cooler at bottle fill	Not detected	Not detected							
15	FCCA-LINK-3-BFB	Bubbler part of bottle fill unit	Not detected	Not detected							
16	FCCA-LINK-2-BF	LINK hall by bathrooms-bottle fill	Not detected	Not detected							
17	FCCA-LINK-4-BFB	High cooler at bottle fill by RR	Not detected	Not detected							
18	FCCA-183W-KF	CR183 work room faucet	Not detected	Not detected							Not filtered
	Continue next page. All fixtures except Rm183 have a lead reduction filter per J. Vannest.										

Take immediate action to reduce the risk of lead exposure in the water at the fixtures with test results that are **BOLD** and highlighed in **RED** in the above table (>0.005 mg/L)

Facility Name: Flint Cultural Center Academy
Building (Entity) Code: 03576

Facility Water Test Results

Lead Testing Grant Program

Date: 8/7/25

			Sample Date: 7/24/25		Sample Date:		Sample Date:		Sample Date:		
Sample Sequence	**Fixture ID Code** (Sample Point field on lab report)	**Fixture Location**	**First Draw Lead Result** (mg/L) as shown on the laboratory report	**30-Second Flush Lead Result** (mg/L) ("F" at end of sample point code is 30 second flush sample)	**First Draw Lead Result** (mg/L) as shown on the laboratory report	**30-Second Flush Lead Result** (mg/L) ("F" at end of sample point code is 30 second flush sample)	**First Draw Lead Result** (mg/L) as shown on the laboratory report	**30-Second Flush Lead Result** (mg/L) ("F" at end of sample point code is 30 second flush sample)	**First Draw Lead Result** (mg/L) as shown on the laboratory report	**30-Second Flush Lead Result (mg/L) ("F" at end of sample point code is 30 second flush sample)**	**Blank test result cells indicate no sample was collected and/or fixture no longer used for consumption**
19	FCCA-2HALL-3-BFB	Bubbler part of bottle fill unit	Not detected	Not detected							
20	FCCA-2HALL-2-BF	Bottle fill-2HALL by CR203	Not detected	Not detected							
21	FCCA-2HALL-4-BFB	High water cooler at bottle fill	Not detected	Not detected							
22	FCCA-2HALL-BFB	Bubbler part of bottle fill unit	Not detected	Not detected							
23	FCCA-2HALL-BF	Bottle fill-2HALL by bathrooms	Not detected	Not detected							
24	FCCA-2HALL-2-BFB	High water cooler at bottle fill	Not detected	Not detected							

Take immediate action to reduce the risk of lead exposure in the water at the fixtures with test results that are **BOLD** and highlighed in **RED** in the above table (>0.005 mg/L)

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77314
Work Order: 50702277_01

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:05
Sample Point:	FCCA-1HALL-3-BFB	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77315
Work Order: 50702277_02

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:05
Sample Point:	FCCA-1HALL-3-BFB-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77316
Work Order: 50702277_03

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:06
Sample Point:	FCCA-1HALL-2-BF	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77317
Work Order: 50702277_04

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:06
Sample Point:	FCCA-1HALL-2-BF-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77318
Work Order: 50702277_05

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:07
Sample Point:	FCCA-1HALL-4-BFB	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77319
Work Order: 50702277_06

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:07
Sample Point:	FCCA-1HALL-4-BFB-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77320
Work Order: 50702277_07

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:13
Sample Point:	FCCA-1HALL-BFB	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77321
Work Order: 50702277_08

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:13
Sample Point:	FCCA-1HALL-BFB-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77322
Work Order: 50702277_09

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:15
Sample Point:	FCCA-1HALL-2-BFB	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77323
Work Order: 50702277_10

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:15
Sample Point:	FCCA-1HALL-2-BFB-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77324
Work Order: 50702277_11

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:14
Sample Point:	FCCA-1HALL-BF	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77325
Work Order: 50702277_12

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:14
Sample Point:	FCCA-1HALL-BF-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77326
Work Order: 50702277_13

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:20
Sample Point:	FCCA-TL-TL	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77327
Work Order: 50702277_14

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:20
Sample Point:	FCCA-TL-TL-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77328
Work Order: 50702277_15

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:24
Sample Point:	FCCA-MST-BFB	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77329
Work Order: 50702277_16

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:24
Sample Point:	FCCA-MST-BFB-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77330
Work Order: 50702277_17

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:25
Sample Point:	FCCA-MST-BF	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77331
Work Order: 50702277_18

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:25
Sample Point:	FCCA-MST-BF-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77332
Work Order: 50702277_19

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:26
Sample Point:	FCCA-MST-2-BFB	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77333
Work Order: 50702277_20

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:26
Sample Point:	FCCA-MST-2-BFB-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77334
Work Order: 50702277_21

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:33
Sample Point:	FCCA-KIT-KF	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77335
Work Order: 50702277_22

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:33
Sample Point:	FCCA-KIT-KF-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77336
Work Order: 50702277_23

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:41
Sample Point:	FCCA-LINK-BFB	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77337
Work Order: 50702277_24

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:41
Sample Point:	FCCA-LINK-BFB-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77338
Work Order: 50702277_25

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:42
Sample Point:	FCCA-LINK-BF	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77339
Work Order: 50702277_26

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:42
Sample Point:	FCCA-LINK-BF-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77340
Work Order: 50702277_27

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:43
Sample Point:	FCCA-LINK-2-BFB	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77341
Work Order: 50702277_28

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:43
Sample Point:	FCCA-LINK-2-BFB-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77342
Work Order: 50702277_29

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:48
Sample Point:	FCCA-LINK-3-BFB	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77343
Work Order: 50702277_30

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:48
Sample Point:	FCCA-LINK-3-BFB-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77344
Work Order: 50702277_31

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:49
Sample Point:	FCCA-LINK-2-BF	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77345
Work Order: 50702277_32

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:49
Sample Point:	FCCA-LINK-2-BF-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77346
Work Order: 50702277_33

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:50
Sample Point:	FCCA-LINK-4-BFB	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77347
Work Order: 50702277_34

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:50
Sample Point:	FCCA-LINK-4-BFB-F	Date Received:	07/24/2025	12:49
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77348
Work Order: 50702277_35

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:56
Sample Point:	FCCA-183W-KF	Date Received:	07/24/2025	12:50
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77349
Work Order: 50702277_36

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	08:56
Sample Point:	FCCA-183W-KF-F	Date Received:	07/24/2025	12:50
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77350
Work Order: 50702277_37

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	09:03
Sample Point:	FCCA-2HALL-3-BFB	Date Received:	07/24/2025	12:50
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77351
Work Order: 50702277_38

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	09:03
Sample Point:	FCCA-2HALL-3-BFB-F	Date Received:	07/24/2025	12:50
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77352
Work Order: 50702277_39

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	09:04
Sample Point:	FCCA-2HALL-2-BF	Date Received:	07/24/2025	12:50
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77353
Work Order: 50702277_40

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	09:04
Sample Point:	FCCA-2HALL-2-BF-F	Date Received:	07/24/2025	12:50
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77354
Work Order: 50702277_41

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	09:05
Sample Point:	FCCA-2HALL-4-BFB	Date Received:	07/24/2025	12:50
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77355
Work Order: 50702277_42

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	09:05
Sample Point:	FCCA-2HALL-4-BFB-F	Date Received:	07/24/2025	12:50
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77356
Work Order: 50702277_43

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	09:07
Sample Point:	FCCA-2HALL-BFB	Date Received:	07/24/2025	12:50
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77357
Work Order: 50702277_44

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	09:07
Sample Point:	FCCA-2HALL-BFB-F	Date Received:	07/24/2025	12:50
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77358
Work Order: 50702277_45

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	09:08
Sample Point:	FCCA-2HALL-BF	Date Received:	07/24/2025	12:50
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77359
Work Order: 50702277_46

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	09:08
Sample Point:	FCCA-2HALL-BF-F	Date Received:	07/24/2025	12:50
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77360
Work Order: 50702277_47

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	09:09
Sample Point:	FCCA-2HALL-2-BFB	Date Received:	07/24/2025	12:50
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

**MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY**
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL77361
Work Order: 50702277_48

System Name/Owner:	3576-FLINT CULTURAL CENTER ACA	WSSN/Pool ID:	2310	
Collection Address:	1200 ROBERT T LONGWAY BLVD,FLINT	Source:	Other	
Collected By:	MOLLY DEKRUGER	Site Code:	WIIN	
Township/Well#/Section:	//	Collector:	Other	
County:	Genesee	Date Collected:	07/24/2025	09:09
Sample Point:	FCCA-2HALL-2-BFB-F	Date Received:	07/24/2025	12:50
Water System:	Other	Purpose:	Other	

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	**Result**	**Units**	**RL**	**Date Tested**	**MCL/AL**	**Method**	**CAS #**
Lead	Not detected	mg/L	0.001	07/29/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Genesee County Health Dept.
630 South Saginaw
Flint, MI 48502-1540
810 257-3603

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane